

ADDENDUM 3

DATE: April 29, 2022

RFP NUMBER: UTA2022-014

RFP DUE DATE: May 12, 2022

The following changes and/or clarifications are hereby incorporated into the RFP. Your proposal must reflect the following:

Change power wash requirement from Addendum 2 to:

Stucco to be washed using a soft washing cleaning method with 12.5% sodium hypochlorite.
Balance of building to be cleaned by UTA.

PLEASE SUBMIT WITH YOUR PROPOSAL

Nancy Czarowitz

Contract Specialist

czarowitz@uta.edu

SIGNED: _____

COMPANY NAME: _____